



Montgomery County Department of Health and Human Services

Licensure and Regulatory Services

255 Rockville Pike, Suite 100; Rockville, Maryland 20850

Phone: 240-777-3986 Fax: 240-777-3088

www.montgomerycountymd.gov/licensure

DAILY SWIMMING POOL HAZARDS CHECKLIST

Name of Facility:

Date:

Address of Facility:

Completed By:

POOL AND DECK

Inspect to confirm the following are in place, properly secured, and in good condition:

- ☐ Main drain/suction outlet covers
- ☐ Vacuum port covers
- ☐ Skimmer lids
- ☐ Equalizer line covers or flush caps (if applicable)
- ☐ Inlet/return covers
- ☐ SVRS or other approved device tested according to manufacturer's instructions and confirmed operational
- ☐ Skimmers (baskets, weirs, and flow adjusters) in good condition and not blocked. Plugs for equalizer lines (if appropriate) properly installed
- ☐ Water in skimmers flowing freely and without blockage
- ☐ Emergency shut off for spa jets labeled and confirmed operational
- ☐ Lifeline installed and in good condition (if applicable)
- ☐ Warning signs posted ("No Diving"; Chemical Storage; Spa Rules)
- ☐ Telephone functional and emergency information posted
- ☐ Main drain clearly visible from the nearest lifeguard chair or the furthest edge of the pool, if the pool has no lifeguard chair

FILTER ROOM

- ☐ All valves and filter piping are labeled and in good condition
- ☐ Vacuum valve closed when not in use
- ☐ Locations of all on/off pump switches are clearly identified.
- ☐ All on/off pump switches are accessible (i.e., not blocked)

****A pool or spa may not operate if any entrapment or entanglement hazard exists**

Corrective Action of an observed hazard: _____
